

EC - DECLARATION OF CONFORMITY **15**

We,

Dwyer Instruments, Inc.
102 Indiana Highway 212
Michigan City, IN 46360 USA
+1-219-879-8868

declare under our sole responsibility that our Series 668B and 668D Differential Pressure Transmitters to which this declaration relates are in conformity with the following Directives and harmonized standards:

Directive 2011/65/EU Restriction of Certain Hazardous Substances in Electrical and Electronic Equipment

Directive 2004/108/EC Electromagnetic Compatibility (EMC)

EN 61326-1:2013 Electrical Equipment for Measurement, Control and Laboratory Use – EMC Requirements Part 1 General Requirements

EN 61000-4-2:2008 Electromagnetic Compatibility (EMC) – Part 4-2: Testing and Measurement Techniques – Electrostatic Discharge Immunity Test

EN 61000-4-3:2006+A1:2008+A2:2010 Electromagnetic Compatibility (EMC) – Part 4-3: Testing and Measurement Techniques – Radiated, Radio-Frequency, Electromagnetic Field Immunity Test

EN 61000-4-8:2010 Electromagnetic Compatibility (EMC) –Part 4-8 Testing and Measurement Techniques – Power Frequency Magnetic Field Immunity Test

CISPR 11:2009+A1:2010 Industrial, Scientific and Medical Equipment – Radio-frequency Disturbance Characteristics – Limits and Methods and Measurement - Radiated Emission (30 Mhz to 1 GHz)

Models included:

668B-XX-YY-Z where XX may be 01, 02, 03, 04, 05, 06, 07, 08, 09, 10, 21, or 22
YY may be 12, 13, 14, 15, 16, 17, 18, or 19
Z may be 1, 2, or 3

668D-XX-YY-Z where XX may be 01, 02, 03, 04, 05, 06, 07, 08, 09, 10, 21, or 22
YY may be 12, 13, 14, 15, 16, 17, 18, or 19
Z may be 1, 2, or 3

The authorized representative located within the Community is:

Dwyer Instruments Ltd
Unit 16 The Wye Estate, London Road
High Wycombe, HP11 1LH-U.K.
+44 (0) 1494 461707

On behalf of Dwyer Instruments, Inc.,



Doug McCall
Authorized Signatory
Senior Regulatory Engineer
Title of Authorized Signatory
October 30, 2015
Date of Signature

Dwyer Instruments, Inc.
102 Indiana Highway 212
Michigan City, IN 46360 USA
+1-219-879-8868