



14

EC - DECLARATION OF CONFORMITY

We,

Dwyer Instruments, Inc.
P.O. Box 373
Michigan City, IN 46361, USA
(219) 879-8868

declare under our sole responsibility that our Model VT-300, Miniature Vane Thermo-Anemometer, to which this declaration relates are in conformity with the following EC Directives and harmonized standards:

Directive 2004/108/EC (EMC)

EN 61326-1 (2006) Electrical Equipment for Measurement, Control, and Laboratory Use- EMC Requirements -Part I: General Requirements

Directive 2011/65/EU (RoHS)

The authorized representative located within the Community is:

Dwyer Instruments Ltd
Unit 16, The Wye Estate, London Road
High Wycombe, Bucks HP11 1LH-U.K.
(+44) (0) 1494 461707

On behalf of Dwyer Instruments, Inc.

Senior Regulatory Engineer

Michigan City, Indiana, USA
7/22/14